



Product Service

Attestation of Conformity

No. N8 15 11 92237 001

Holder of Certificate: **WISAR, Wyser + Anliker AG**

Steinackerstraße 10
8302 Kloten
SWITZERLAND

Product: **Switchgear Cabinets**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 028-713063040-000

Date, 2015-11-03

(Thomas Kokorsch)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity
No. N8 15 11 92237 001

Model(s):

Serien:

brüco Modem-Schrank
brüco Combi- / VR-Schrank
brüco economy-Schrank
brüco fix-Schrank,
brüco dynamics / Rack Schrank
brüco Wand- / Standgehäuse
brüco Optimo
brüco ALS 9000
brüco Systembau
brüco Easy Cool

Parameters:

Rated voltage:	230 V AC or 3/N/PE 400 V AC
Rated frequency:	50 Hz
Rated power:	depending on Equipment (max. per phase 16 A or 3680 W)
Protection class:	I
Degree of protection:	IP20

Tested
according to:

EN 61439-1:2011
EN 62208:2011